
ALLEN-BRADLEY

ControlNet Network Access Cable

(Cat. No. 1786-CP)


Installation Instructions


Use the ControlNet™ Network Access cable (1786-CP) to connect a programming device to any intelligent device (i.e. workstation, PLC® processor, scanner or adapter) on ControlNet through the network access port ( ).



20139

Connections






This cable is not a straight-through cable.

Installation Instructions
ControlNet Network Access Cable
1786-CP

ATTENTION: Do not use the1786-CP cable to provide more than one connection to your ControlNet cable system; this connection could result in possible network failures.



For additional information on making connections to ControlNet, see the *ControlNet Cable System Planning and Installation Manual* (publication 1786-6.2.1).

ControlNet is a trademark; PLC is a registered trademark of Allen-Bradley, Inc.

ALLEN-BRADLEY
A ROCKWELL INTERNATIONAL COMPANY
With offices in major cities worldwide

Publication 1786-2.6 — March 1994
PN 955116-79
Copyright 1994 Allen-Bradley Company, Inc. Printed in USA