Honeywell

EXPERION PKS

RELEASE 515

Fault Tolerant Ethernet Bridge Implementation Guide

EPDOC-XX35-en515A

November 2019

3.1.4 Installing FTE Bridge module (TC-FTEB01/TK-FTEB01)

> **ATTENTION**
>
> The following procedure assumes that the chassis has been installed and grounded as outlined in the Control Hardware Installation Guide, and power is not applied.

To insert the FTE Bridge module into the chassis

1. Align the module's circuit board with the top and bottom chassis guides for the planned slot location. Typically, slot 0 is reserved for the communication module. (Remember that slot numbering is zero-based and the left most slot is number "0".)

